

ADDENDUM NO. 1

CHATTANOOGA HOUSING AUTHORITY
CONTRACTOR SERVICES FOR
RENOVATION OF FIRE DAMAGED ADMINISTRATION BUILDING
AT COLLEGE HILL COURTS
INVITATION FOR BID (IFB) #D-307-01

The Chattanooga Housing Authority (CHA) is hereby issuing Addendum No. 1 to the above project. This Addendum consists of Five (5) items and two (2) pages as follows:

Corrections and Changes:

CORRECTION:

1. BID FORM – Page 2 under LIQUIDATED DAMAGES, change day 15 to day 91.

CHANGES:

2. **Change** material where new ceiling is requesting “Two coat plaster over metal lath” and “Thin coat plaster (no lath)” to new **One (1) hour rated acoustical ceiling tile system**. This change affects lines #25, 26, 65, and 66. **NOTE: MC cable may be used over new rated ceiling system.**
3. **Delete** lines #7 and 46 - Suspended ceiling system. The above rated ceiling eliminates this item.
4. **Increase** attic insulation where requested from **R-20 to R-38**. This affects lines #23, 63, 84, 100, 118, 136, 153, 174, 193, 216, 241, 265, and 285. Just strike out R-20 and write in R-38.
5. **New Additional Item:** Add **R-38** insulation to the remaining portion of the building attic approximately 1,950 SF. Just write in new line and dollar amount at end of Scope of Work pages.

NOTE: The Insurance company is requesting that all contractors submitting a bid complete the scope of work pages by including unit prices and item totals by each line item and submitting with the bid with the total bid amount on the Bid Form.

Please acknowledge Addendum on the bid form.

The original signed acknowledgment form must be returned to CHA.

DATED: 6/9/10

ACKNOWLEDGMENT

I acknowledge receipt of ADDENDUM NO. 1 to the Invitation to Bid (IFB) #D-307-01 for CONTRACTORS SERVICES FOR RENOVATION OF FIRE DAMAGED ADMINISTRATION BUILDING AT COLLEGE HILL COURTS.

(Signed)

(Company)

(Date)

PLEASE INCLUDE WITH YOUR SEALED BID.